PRESSURE REDUCING VALVE Type 7BIS





Technical description

- Operating temperature Mini. : -10 °C / Maxi. in permanent service : 80 °C
- Permissible operating pressure (PFA) in water : See table above
- Maximum permissible pressure (PS) other mediums : See table above
- Connection : Female/female, BSP
- Gauge connection 1/4"
- Mediums EPDM : water Other mediums : consult us

Nomenclature and material

The Desbordes pressure reducing valves 7 BIS bodies are made of bronze. Due to the design, they are not affected by scale or dirt and do not need any maintenance. They can be fitted on compressed air, neutral gases and fuel oil at ambient temperature circuits. For these cases of applications consult us.

• Control and maintain the downstream pressure at an adjustable reduced value, whether there is a flow or not

Keep an outlet pressure at a constant value, even by variation of the upstream pressure (the downstream pressure can not vary more than 10 % of the variation of the upstream pressure, according to the Standard) Guarantee a high flow rate at a constant outlet pressurebecause of low headloss
Downstream setting : 1 bar to 5,5 bar ; indicative value according to EN1567


Pre-set at 3 bar


• Equipped with 2 plugs 1/4" on each side to allow the mounting of downstream pressure gauge and drain

DN		PFA		PS in bar			Cat.	Ref.		Weight
22	mm	in bar	L1	L2	G1	G2	Cal.	Water	Other mediums	Kg
1/2	15	16	16	16	х	16	4.3	149B7209	149B7756	0,50
3/4	20	16	16	16	х	16	4.3	149B7210	149B7757	0,60
1	25	16	16	16	х	16	4.3	149B7552	149B7758	0,95
1 1/4	32	16	16	16	х	16	4.3	149B7553	149B7759	1,55
1 1/2	40	16	16	16	х	16	4.3	149B7554	149B7760	2,05
2	50	16	16	16	х	16	4.3	149B7555	149B7761	3,70

Important notice : L1, L2, G1 and G2 correspond to liquids/gas classified into degree of danger according to the Pressure Equipment Directive (PED). The article 4.3 applies to equipments with no CE marking.

N°	Designation		Materials	EURO	ANSI		
1	Body		Bronze	EN1982 CuSn5Zn5Pb5-C GS	ASTM B 505		
2	Stem		DZR Brass	EN12164 CuZn36Pb2As R350			
3	Seal box		Brass	EN12164 CuZn39Pb3 R360 mini	ASTM B 124		
4	Seel	DN 15-20 mm	EPDM or NBR				
4	Seal	DN 25-50 mm	NBR				
F	Membrane	Water	EPDM				
5	wennbrane	Other mediums	FKM				
6	Membrane w	vasher	Brass	EN12164 CuZn39Pb3 R360 mini	ASTM B 124		
7	Nut		Stainless steels	EN10088-3 X5CrNi 18-10	AISI 304		
8	Spring		Anticorrosive steel	EN10270-1 SH			
9	Сар		Brass or Zamak	EN12165 CuZn40Pb2 H080 Zamak ZP5	ASTM B 124		
10	Screw		Stainless steel	EN10088-3 X5CrNi 18-10	AISI 304		
11	Adjusting scr	ew	Brass	EN12164 CuZn39Pb3 R360 mini	ASTM B 124		
12	Plug cap		Brass	EN12164 CuZn39Pb3 R360 mini	ASTM B 124		
13	Flat seal		NBR (Nitrile)				
14	Pressure gau	uge plug	Brass	EN12164 CW617N R360 mini	ASTM B 124		
15	O-ring		EPDM or NBR				
16 Plug		Plastic		PB 180 G2M			
			or Brass	CuZn40Pb2			
17*	O-ring		EPDM or NBR				





*To DN 32 at 50mm only

PRESSURE REDUCING VALVE

Type 7BIS



Application

7 BIS is an ideal pressure reducing valve for domestic water systems without special requirements : individual supply for building sites (flats, houses...).

Factory preset at 3 bar, it protects the whole installation, facilitates the setting of mixing valves, and decreases the hammeringand helps to avoid cracks and vibrations in the piping.

Thanks to its weak head losses, it helps to obtain normal flow during simultaneous pumping.

Installation

In domestic water supply the DESBORDES 7 BIS reducing valves are fitted just after the water meter and thus protect the whole installation. They can be fitted wherever a reducing pressure is needed.

If there is a frost risk, they should be drained.

It can be fitted in any positions (horizontal, upright, upside down, fluid ascending or reversed and inclined...) if you respect the direction of flow as indicated by the arrow engraved on the body. However if the circuit present a risk of back pressure or hammering we recommend to protect the pressure reducing valve with a check valve directly after its output.

Fonctionnement

Flow :

During water flow, water pressure exercised on the diaphragm decreases, which allows the spring to relax. The piston disc-yoke assembly moves towards the bottom to allow the water to pass.


Flow stoppage :

When water flow stops, the downstream pressure pushes on the diaphragm again, the spring goes back to its initial position, which leads to the valve closing, stopping water from flowing freely.

Setting

The adjustment must be done without flow ie no downstream outflow. The 7 BIS pressure reducing valve is factory pre-set at3 bar. They remain adjustable within a 1,5 bar to 5.5 bar range. To increase the pressure, tighten the adjusting screw (clockwise as you look at the screw from above). To reduce the pressure, undo the adjusting screw (anticlockwise as you look at the screw from above), slightly open a tap for a moment, close again, then tighten the screw again until you obtain a desired pressure. Water hammers can damage the reducing valve. When commissionning, open slowly and gradualy the valve at the upstream side. A booster unit with a sudden start close to the pressure reducer requires the safety of an absorption tank. Just like by any intervention on the pipe work, the circuits must be rinsed beforhand.

Max. upstream pressure : 16 bar.



DN (mm)	Kv	Q max	Q at 2 m/s
15	2	3,5	1,27
20	3	5,8	2,26
25	3,1	6,2	3,53
32	5,5	10	5,8
40	9,3	13,5	9
50	17,4	30	14

Kv : Flow in m3/h when the output pressure becomes 1 bar lower than its zero flow setting

7 BIS - Headloss chart

Sizing

-						
DN	C)	A	В	С	G
mm	» mm		mm	mm	mm	mm
15	1/2	15/21	30	56	64,5	50
20	3/4	20/27	33,5	61	70	57
25	1	26/34	30	68	81	70
32	1 1/4	33/42	34,5	91	97	81
40	1 1/2	40/49	36,5	106	110	92
50	2	50/60	45,5	106	135	120

